



**NOTICE OF AUTHORIZATION TO APPLY THE UL MARK**

2007-07-02

Mr. Frank Hsu  
Aaeon Technology Inc  
C/O Superior Product Consulting Inc

E-mail: [frank@spci.com.tw](mailto:frank@spci.com.tw)

Reference: File E241995 Project 07CA10552

Product: USC/CNC- Medical Display: ONYX-219 SERIES, WITH ALTERNATE DISPLAY PANEL.

Dear Mr. Hsu,

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

UL's investigation of your product has been completed under the above project number and the subject product was determined to comply with the applicable requirements.

This letter temporarily supplements the UL Follow-Up Services Procedure and serves as authorization to apply the UL Classification Mark only at the factory under UL's Follow-Up Service Program to the subject product, which is constructed as described below:

Identical to the subject model, which was submitted to UL for this investigation. The UL Records covering the product will be in the Follow-Up Services Procedure, File E241995-A11, Volume X1.

To provide the manufacturer with the intended authorization to use the UL Mark, the addressee must send a copy of this Notice and all attached material to each manufacturing location as currently authorized in File E241995-A11, Volume X1.

This authorization is effective from the date of this Notice and only for products at the indicated manufacturing locations. Records in the Follow-Up Services Procedure covering the product are now being prepared and will be sent to the indicated manufacturing locations in the near future. Please note that Follow-Up Services Procedures are sent to the manufacturers only unless the Applicant specifically requests this document.

Products that bear the UL Mark shall be identical to those that were evaluated by UL and found to comply with UL's requirements. If changes in construction are discovered, appropriate action will be taken for products not in conformance with UL's requirements and continued use of the UL Mark may be withdrawn.

Sincerely,

Reviewed by:

Deborah L. Stubbs  
Senior Project Engineer  
Department: 3016LSCL  
Tel: 408-754-6724  
Fax: 408-689-6724  
E-mail: [Deborah.L.Stubbs@us.ul.com](mailto:Deborah.L.Stubbs@us.ul.com)

Michael J. Howell  
Senior Project Engineer  
Department: 3016LSCL  
E-mail: [Michael.J.Howell@us.ul.com](mailto:Michael.J.Howell@us.ul.com)

